

417th Base Support Battalion

Commander's Policy

Policy Number: 6-3 Proponent: AETV-WG-WM Date: 7 August 2003

SUBJECT: Heating Policy

1. REFERENCES:

- a. AR 420-49, 28 May 97, Utilities Services.
- b. USAREUR Regulation 11-27, 3 Feb 97, Energy Program.
- c. Executive Order 13123, 3 Jun 99, Greening the Government
- 2. PURPOSE: To prescribe procedures for the 417th Base Support Battalion (BSB) Heating Policy.
- 3. SCOPE: This policy applies to all facilities within the 417th BSB community.

4. POLICY:

- a. Heat: The 417th BSB will not supply heat to living quarters, installation facilities, and related areas from 1 June through 31 August. Heat will be supplied between 1 September and 31 May when the average daily outside temperature has been 60 degrees Fahrenheit (F) or 16 degrees Celsius (C) for 48 consecutive hours. When heat is provided, the room temperature for facilities will not exceed the following:
 - Child Care and Medical Facilities 72F/22C.
- (2) Living Quarters (Family Housing) 72F/22C (days), 60F/16C (nights -2300-0600 hrs).
- (3) Offices 70F/21C (working hours), not more than 55F/13C (non-working hours).
- (4) Warehouses, shops, hangars and other buildings where many employees work in a standing position exercising moderately 55F/13C.
- (5) Warehouses, shops, and hangars will not be heated if they usually are devoid of human activity and if freezing or condensation are not problems.

AETV-WG-WM SUBJECT: Heating Policy, 6-3

- b. Hot Water Temperatures: Water temperature for shower facilities will not exceed 110F. Hot water temperatures required for the following uses are exempt, but thermostats will not be set higher than required by applicable regulations:
 - (1) Industrial and manufacturing processes.
 - (2) Medical facilities, child care centers, and food handling operations.
- c. The Area Support Group Commander has ultimate authority to make exceptions to the space heating policy. Forward requests through the Area Support Team and 417th BSB Commander.
- 5. PROPONENT: 417th BSB, Directorate of Public Works, DSN 351-1560.

LTC, EN

Commanding